



**NOTES:**

1. CONCRETE STANDARD:  
32MP<sub>a</sub> DURA-MIX CONCRETE  
5-8% AIR AS PER COS SPEC.
2. COMPACTION STANDARD:  
98% STANDARD PROCTOR AS PER COS SPEC.
3. BROOM FINISH TOP & FACE OF CURB AND GUTTER LONGITUDINALLY.  
BROOM OVER ALL CONTROL JOINTS.
4. SPACING OF CONTROL JOINTS TO BE 1.5m.
5. IF PAVER LIP IS NOT INTEGRALLY Poured IT MUST BE PINNED TO CURB & GUTTER AS PER STANDARD COS SPEC.

PLAN DESCRIPTION/REVISION			DATE	BY	APPROVALS	
1	ORIGINAL STANDARD DRAWING		2014-DEC-15	DJC	<i>Chris Duriez</i>	<i>Maciej Jurkiewicz</i>
2	UPDATED TO ALIGN WITH SIDEWALK BEST PRACTICES REPORT		2020-OCT-06	DLH	Christopher Duriez	Maciej Jurkiewicz
					NAME	NAME
					Jan 25, 2021	Jan 25, 2021
					DATE SIGNED	DATE SIGNED
					SCALES:	PLAN NO.
					HOR. 1:10	102-0002-067r002
					VERT.	



150mm VERTICAL CURB & GUTTER  
WITH PAVER LIP